



Electrical • Instrumentation • SCADA

## CALIBRATION REPORT

### Calibration Equipment Used

DATE : April 1, 2014  
COMPANY : RJV Gasfield Services  
S / N : 2014040101  
TECH : Justin Greene

|                                        | Serial # |
|----------------------------------------|----------|
| Fluke 744 Process Calibrator           | 9259024  |
| Fluke 700P06 100 psi Pressure Module   | 92650647 |
| Fluke 700P31 10000 psi Pressure Module | 17913109 |

SIGNATURE:

*Justin Greene*

### INSTRUMENT INFORMATION

|                                  |                           |
|----------------------------------|---------------------------|
| Manufacturer: Swagelok           | Model Number: SS-4R3A5-EP |
| Calibration Date: April 1, 2014  | Range: 3000 - 4000 psi    |
| Device Purpose: POP Relief Valve |                           |

### CALIBRATION DATA

| TRIP POINT RISING | TRIP POINT FALLING | AS FOUND | AS LEFT         |
|-------------------|--------------------|----------|-----------------|
| 3695 psi          | N/A                | N/A      | 3695 psi rising |
|                   |                    |          |                 |

NOTES :

Installed 3000 - 4000 psi spring and set.

---

---

---

---

---



## CALIBRATION REPORT

### Calibration Equipment Used

DATE : April 1, 2014  
COMPANY : RJV Gasfield Services  
S / N : 2014040102  
TECH : Justin Greene

|                                        | Serial # |
|----------------------------------------|----------|
| Fluke 744 Process Calibrator           | 9259024  |
| Fluke 700P06 100 psi Pressure Module   | 92650647 |
| Fluke 700P31 10000 psi Pressure Module | 17913109 |

SIGNATURE:

*Justin Greene*

### INSTRUMENT INFORMATION

|                                  |                           |
|----------------------------------|---------------------------|
| Manufacturer: Swagelok           | Model Number: SS-4R3A5-EP |
| Calibration Date: April 1, 2014  | Range: 3000 - 4000 psi    |
| Device Purpose: POP Relief Valve |                           |

### CALIBRATION DATA

| TRIP POINT RISING | TRIP POINT FALLING | AS FOUND | AS LEFT         |
|-------------------|--------------------|----------|-----------------|
| 3695 psi          | N/A                | N/A      | 3695 psi rising |
|                   |                    |          |                 |

NOTES :

Installed 3000 - 4000 psi spring and set.



## CALIBRATION REPORT

### Calibration Equipment Used

DATE : April 1, 2014  
COMPANY : RJV Gasfield Services  
S / N : 2014040103  
TECH : Justin Greene

|                                        | Serial # |
|----------------------------------------|----------|
| Fluke 744 Process Calibrator           | 9259024  |
| Fluke 700P06 100 psi Pressure Module   | 92650647 |
| Fluke 700P31 10000 psi Pressure Module | 17913109 |

SIGNATURE:

*Justin Greene*

### INSTRUMENT INFORMATION

|                                  |                           |
|----------------------------------|---------------------------|
| Manufacturer: Swagelok           | Model Number: SS-4R3A5-EP |
| Calibration Date: April 1, 2014  | Range: 3000 - 4000 psi    |
| Device Purpose: POP Relief Valve |                           |

### CALIBRATION DATA

| TRIP POINT RISING | TRIP POINT FALLING | AS FOUND | AS LEFT         |
|-------------------|--------------------|----------|-----------------|
| 3190 psi          | N/A                | N/A      | 3190 psi rising |
|                   |                    |          |                 |

NOTES :

Installed 3000 - 4000 psi spring and set.

---

---

---

---

---



## CALIBRATION REPORT

### Calibration Equipment Used

DATE : April 1, 2014  
COMPANY : RJV Gasfield Services  
S / N : 2014040104  
TECH : Justin Greene

|                                        | Serial # |
|----------------------------------------|----------|
| Fluke 744 Process Calibrator           | 9259024  |
| Fluke 700P06 100 psi Pressure Module   | 92650647 |
| Fluke 700P31 10000 psi Pressure Module | 17913109 |

SIGNATURE:

*Justin Greene*

### INSTRUMENT INFORMATION

|                                  |                           |
|----------------------------------|---------------------------|
| Manufacturer: Swagelok           | Model Number: SS-4R3A5-EP |
| Calibration Date: April 1, 2014  | Range: 3000 - 4000 psi    |
| Device Purpose: POP Relief Valve |                           |

### CALIBRATION DATA

| TRIP POINT RISING | TRIP POINT FALLING | AS FOUND | AS LEFT         |
|-------------------|--------------------|----------|-----------------|
| 3190 psi          | N/A                | N/A      | 3190 psi rising |
|                   |                    |          |                 |

NOTES :

Installed 3000 - 4000 psi spring and set.



Electrical • Instrumentation • SCADA

## CALIBRATION REPORT

### Calibration Equipment Used

DATE : April 1, 2014  
COMPANY : RJV Gasfield Services  
S / N : 2014040105  
TECH : Justin Greene

|                                        | Serial # |
|----------------------------------------|----------|
| Fluke 744 Process Calibrator           | 9259024  |
| Fluke 700P06 100 psi Pressure Module   | 92650647 |
| Fluke 700P31 10000 psi Pressure Module | 17913109 |

SIGNATURE:

*Justin Greene*

### INSTRUMENT INFORMATION

|                                  |                           |
|----------------------------------|---------------------------|
| Manufacturer: Swagelok           | Model Number: SS-4R3A5-EP |
| Calibration Date: April 1, 2014  | Range: 3000 - 4000 psi    |
| Device Purpose: POP Relief Valve |                           |

### CALIBRATION DATA

| TRIP POINT RISING | TRIP POINT FALLING | AS FOUND | AS LEFT         |
|-------------------|--------------------|----------|-----------------|
| 3190 psi          | N/A                | N/A      | 3190 psi rising |
|                   |                    |          |                 |

NOTES :

Installed 3000 - 4000 psi spring and set.





## CALIBRATION REPORT

### Calibration Equipment Used

DATE : April 1, 2014  
COMPANY : RJV Gasfield Services  
S / N : 2014040106  
TECH : Justin Greene

|                                        | Serial # |
|----------------------------------------|----------|
| Fluke 744 Process Calibrator           | 9259024  |
| Fluke 700P06 100 psi Pressure Module   | 92650647 |
| Fluke 700P31 10000 psi Pressure Module | 17913109 |

SIGNATURE:

### INSTRUMENT INFORMATION

|                                  |                           |
|----------------------------------|---------------------------|
| Manufacturer: Swagelok           | Model Number: SS-4R3A5-EP |
| Calibration Date: April 1, 2014  | Range: 3000 - 4000 psi    |
| Device Purpose: POP Relief Valve |                           |

### CALIBRATION DATA

| TRIP POINT RISING | TRIP POINT FALLING | AS FOUND | AS LEFT         |
|-------------------|--------------------|----------|-----------------|
| 3190 psi          | N/A                | N/A      | 3190 psi rising |
|                   |                    |          |                 |

NOTES :

Installed 3000 - 4000 psi spring and set.



Electrical • Instrumentation • SCADA

## CALIBRATION REPORT

### Calibration Equipment Used

DATE : April 1, 2014  
COMPANY : RJV Gasfield Services  
S / N : 2014040107  
TECH : Justin Greene

|                                        | Serial # |
|----------------------------------------|----------|
| Fluke 744 Process Calibrator           | 9259024  |
| Fluke 700P06 100 psi Pressure Module   | 92650647 |
| Fluke 700P31 10000 psi Pressure Module | 17913109 |

SIGNATURE:

Justin Greene

### INSTRUMENT INFORMATION

|                                  |                           |
|----------------------------------|---------------------------|
| Manufacturer: Swagelok           | Model Number: SS-4R3A5-EP |
| Calibration Date: April 1, 2014  | Range: 3000 - 4000 psi    |
| Device Purpose: POP Relief Valve |                           |

### CALIBRATION DATA

| TRIP POINT RISING | TRIP POINT FALLING | AS FOUND | AS LEFT         |
|-------------------|--------------------|----------|-----------------|
| 3190 psi          | N/A                | N/A      | 3190 psi rising |
|                   |                    |          |                 |

NOTES :

Installed 3000 - 4000 psi spring and set.

---

---

---

---

---



## CALIBRATION REPORT

### Calibration Equipment Used

DATE : April 1, 2014  
COMPANY : RJV Gasfield Services  
S / N : 2014040108  
TECH : Justin Greene

|                                        | Serial # |
|----------------------------------------|----------|
| Fluke 744 Process Calibrator           | 9259024  |
| Fluke 700P06 100 psi Pressure Module   | 92650647 |
| Fluke 700P31 10000 psi Pressure Module | 17913109 |

SIGNATURE:

### INSTRUMENT INFORMATION

|                                  |                           |
|----------------------------------|---------------------------|
| Manufacturer: Swagelok           | Model Number: SS-4R3A5-EP |
| Calibration Date: April 1, 2014  | Range: 3000 - 4000 psi    |
| Device Purpose: POP Relief Valve |                           |

### CALIBRATION DATA

| TRIP POINT RISING | TRIP POINT FALLING | AS FOUND | AS LEFT         |
|-------------------|--------------------|----------|-----------------|
| 3190 psi          | N/A                | N/A      | 3190 psi rising |
|                   |                    |          |                 |

NOTES :

Installed 3000 - 4000 psi spring and set.

---

---

---

---

---





Electrical • Instrumentation • SCADA

## CALIBRATION REPORT

### Calibration Equipment Used

DATE : April 1, 2014  
COMPANY : RJV Gasfield Services  
S / N : 2014040109  
TECH : Justin Greene

|                                        | Serial # |
|----------------------------------------|----------|
| Fluke 744 Process Calibrator           | 9259024  |
| Fluke 700P06 100 psi Pressure Module   | 92650647 |
| Fluke 700P31 10000 psi Pressure Module | 17913109 |

SIGNATURE:

Justin Greene

### INSTRUMENT INFORMATION

|                                  |                           |
|----------------------------------|---------------------------|
| Manufacturer: Swagelok           | Model Number: SS-4R3A5-EP |
| Calibration Date: April 1, 2014  | Range: 2250 - 3000 psi    |
| Device Purpose: POP Relief Valve |                           |

### CALIBRATION DATA

| TRIP POINT RISING | TRIP POINT FALLING | AS FOUND | AS LEFT         |
|-------------------|--------------------|----------|-----------------|
| 2291 psi          | N/A                | N/A      | 2291 psi rising |
|                   |                    |          |                 |

NOTES :

Installed 2250 - 3000 psi spring and set.

---

---

---

---

---



Electrical • Instrumentation • SCADA

## CALIBRATION REPORT

### Calibration Equipment Used

DATE : April 1, 2014  
COMPANY : RJV Gasfield Services  
S / N : 2014040110  
TECH : Justin Greene

|                                        | Serial # |
|----------------------------------------|----------|
| Fluke 744 Process Calibrator           | 9259024  |
| Fluke 700P06 100 psi Pressure Module   | 92650647 |
| Fluke 700P31 10000 psi Pressure Module | 17913109 |

SIGNATURE:

### INSTRUMENT INFORMATION

|                                  |                           |
|----------------------------------|---------------------------|
| Manufacturer: Swagelok           | Model Number: SS-4R3A5-EP |
| Calibration Date: April 1, 2014  | Range: 750 - 1500 psi     |
| Device Purpose: POP Relief Valve |                           |

### CALIBRATION DATA

| TRIP POINT RISING | TRIP POINT FALLING | AS FOUND | AS LEFT         |
|-------------------|--------------------|----------|-----------------|
| 1363 psi          | N/A                | N/A      | 1363 psi rising |
|                   |                    |          |                 |

NOTES :

Installed 750 - 1500 psi spring and set.



## CALIBRATION REPORT

### Calibration Equipment Used

DATE : April 1, 2014  
COMPANY : RJV Gasfield Services  
S / N : 2014040111  
TECH : Justin Greene

|                                        | Serial # |
|----------------------------------------|----------|
| Fluke 744 Process Calibrator           | 9259024  |
| Fluke 700P06 100 psi Pressure Module   | 92650647 |
| Fluke 700P31 10000 psi Pressure Module | 17913109 |

SIGNATURE:

### INSTRUMENT INFORMATION

|                                  |                           |
|----------------------------------|---------------------------|
| Manufacturer: Swagelok           | Model Number: SS-4R3A5-EP |
| Calibration Date: April 1, 2014  | Range: 750 - 1500 psi     |
| Device Purpose: POP Relief Valve |                           |

### CALIBRATION DATA

| TRIP POINT RISING | TRIP POINT FALLING | AS FOUND | AS LEFT         |
|-------------------|--------------------|----------|-----------------|
| 1440 psi          | N/A                | N/A      | 1440 psi rising |
|                   |                    |          |                 |

NOTES :

Installed 750 - 1500 psi spring and set.



## CALIBRATION REPORT

### Calibration Equipment Used

DATE : April 1, 2014  
COMPANY : RJV Gasfield Services  
S / N : 2014040112  
TECH : Justin Greene

|                                        | Serial # |
|----------------------------------------|----------|
| Fluke 744 Process Calibrator           | 9259024  |
| Fluke 700P06 100 psi Pressure Module   | 92650647 |
| Fluke 700P31 10000 psi Pressure Module | 17913109 |

SIGNATURE:

*Justin Greene*

### INSTRUMENT INFORMATION

|                                  |                           |
|----------------------------------|---------------------------|
| Manufacturer: Swagelok           | Model Number: SS-4R3A5-EP |
| Calibration Date: April 1, 2014  | Range: 750 - 1500 psi     |
| Device Purpose: POP Relief Valve |                           |

### CALIBRATION DATA

| TRIP POINT RISING | TRIP POINT FALLING | AS FOUND | AS LEFT         |
|-------------------|--------------------|----------|-----------------|
| 1438 psi          | N/A                | N/A      | 1438 psi rising |
|                   |                    |          |                 |

NOTES :

Installed 750 - 1500 psi spring and set.



## CALIBRATION REPORT

### Calibration Equipment Used

DATE : April 1, 2014  
COMPANY : RJV Gasfield Services  
S / N : 2014040113  
TECH : Justin Greene

|                                        | Serial # |
|----------------------------------------|----------|
| Fluke 744 Process Calibrator           | 9259024  |
| Fluke 700P06 100 psi Pressure Module   | 92650647 |
| Fluke 700P31 10000 psi Pressure Module | 17913109 |

SIGNATURE:

*Justin Greene*

### INSTRUMENT INFORMATION

|                                  |                           |
|----------------------------------|---------------------------|
| Manufacturer: Swagelok           | Model Number: SS-4R3A5-EP |
| Calibration Date: April 1, 2014  | Range: 750 - 1500 psi     |
| Device Purpose: POP Relief Valve |                           |

### CALIBRATION DATA

| TRIP POINT RISING | TRIP POINT FALLING | AS FOUND | AS LEFT         |
|-------------------|--------------------|----------|-----------------|
| 1438 psi          | N/A                | N/A      | 1438 psi rising |
|                   |                    |          |                 |

NOTES :

Installed 750 - 1500 psi spring and set.

---

---

---

---

---